



**HURON COUNTY GENERAL HEALTH DISTRICT**  
Timothy Hollinger, MPH, Health Commissioner

180 Milan Avenue, Suite 8  
Norwalk, OH 44857  
e-mail: [information@huroncohealth.com](mailto:information@huroncohealth.com)

419-668-1652 or 1-888-694-2443 Toll-Free  
419-668-5423 General Fax  
419-660-0129 Environmental Health Fax

---

## **PRIVATE WATER SYSTEMS - COMMERCIAL TYPE STRUCTURES**

(i.e., meeting halls, churches, multi-family dwellings, or single family using ponds, etc.)

### **SYSTEM SITE PLAN REQUIREMENTS**

1. INCLUDE INFORMATION AS TO THE NUMBER OF INDIVIDUALS TO BE SERVED BY THE WATER SYSTEM.
2. MUST BE LEGIBLE AND DRAWN TO SCALE WITH A NORTH DIRECTIONAL ARROW.
3. MUST INCLUDE ELEVATIONS OF THE PROPERTY TO 5 OR 10-FOOT INTERVALS.
4. SHOW THE LOCATIONS, LAYOUT, AND TYPE OF ALL WATER SYSTEM EQUIPMENT.
5. INCLUDE ALL DISTANCE INFORMATION AS LISTED TO THE RIGHT OF THE DRAWING PLAN APPLICATION.
6. INCLUDE A LISTING OF ALL MATERIALS TO BE USED IN CONSTRUCTION, INSTALLATION, OR ALTERATION OF THE WATER SYSTEM.
7. SHOW THE LAYOUT AND PROFILE OF THE WATER DISTRIBUTION PIPING FROM THE SOURCE TO THE SERVICE CONNECTIONS.
8. THIS IS A CARBONLESS FORM; DO THE INITIAL/DRAFT DRAWING ON REGULAR PAPER TO PREVENT MISTAKES.

EXAMPLE

Ohio Department of Health

# Application/Permit for Private Water System Site Plan

Health district	Huron County	Permit number	#
Owner/Applicant	Sample Drawing		
Location of property	123 Happy Highway Norwalk Twp Norwalk, Ohio		
Site plan prepared by	Sunshine Drilling		

Clearly indicate the location or area of the proposed or existing private water system. Please indicate scale.

↑ North scale  $\frac{1}{2}'' = 10'$

**Check List**

- Location of PWS or Test Hole
- Road right-of-ways
- Existing or properly sealed water wells
- Above or below ground storage tanks
- Property lines
- Public roadways
- Driveways
- Easements
- Sewer lines
- Sewage disposal systems
- Buildings
- Houses
- Barn or feed lots
- Outbuildings
- Oil and gas wells
- Streams, lake, ponds and ditches
- Manure ponds, lagoons or piles
- Lot lines
- Land fills
- Other possible sources of contamination

Comments  
Number people to be served - 4  
well casing made of PVC piping, grout - bentonite

**PLEASE NOTE: Any changes to the site plan must be approved by the local health district**